

- GRADE OF CONNECTION TO BE NOT LESS THAN 2%.
- WHEN ROCK IS ENCOUNTERED IN SERVICE TRENCH EXCAVATE AND BACKFILL A MINIMUM OF 1.5 m BEYOND END OF SERVICE.
- MIN. I.O m COVER AT R OR SUFFICIENT TO PICK UP BASEMENT PLUMBING, WHICH EVER IS GREATER.

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TOWN OF LADYSMITH ENGINEERING STANDARD

SANITARY & STORM SEWER SERVICE CONNECTION

DATE: MAY 1996

APP. BY:

DRAWING No. REV.

S5 01