

2014 E-Coli & Total Coliforms Results

Source (Untreated) Water E-Coli and Total Coliform Results Holland Lake

Parameter	No of Samples	Units	Ave	High	Low	Samples > 20 (e-coli)	Comments
E-Coli	22	Cfu/100ml	1.67	4	<1	0.0% > 20 cfu/100ml	10% max
Total Coliforms	22	Cfu/100ml	495.29	1900	7	68% > 100 cfu/100ml	

Source Water E-Coli and Total Coliform Results Holland Creek (Chicken Ladder)

Parameter	No of Samples	Units	Ave	High	Low	Samples > 20 (e-coli)	Comments
E-Coli	23	Cfu/100ml	17.88	69	<1	21.7% > 20 cfu/100ml	10% max Over Regulated allowable limit
Total Coliforms	23	Cfu/100ml	346.17	990	16	71% >100 cfu/100ml	

Source Water E-Coli and Total Coliform Results Stocking Lake

Parameter	No of Samples	Units	Ave	High	Low	Samples > 20 (e-coli)	Comments
E-Coli	22	Cfu/100ml	3.11	13	<1	0% > 20 cfu/100ml	10% max
Total Coliforms	22	Cfu/100ml	387.62	1600	<1	34% > 100 cfu/100ml	