

2014 THM Formation in Water System, in mg/L

	558 Hooper	1280 Rocky Creek	CDW Guideline	Comments
Date	THM	THM		
Mar.5/14	0.063	0.054	0.100	Marginally meets CDWG
Jun.16/14	0.051	0.051	0.100	Marginally meets CDWG
Sept.24/14	0.059	0.054	0.100	Marginally meets CDWG
Dec.12/14	0.0	0.0	0.100	Marginally meets CDWG

2014 Total HAA Formation in Water System, in mg/L

	558 Hooper	1280 Rocky Creek	CDW Guideline	Comments
Mar 5, 14	0.100	0.081	0.080	Marginally Fails CDWG
Jun.16/14	0.082	0.079	0.080	Marginally Fails CDWG
Oct. 6/14	0.082	0.056	0.080	Marginally Meets CDWG
Dec.12/14	0.079	0.070	0.080	Marginally Meets CDWG

THM Component Results, in mg/L

Test Date	Component	558 Hooper	1280 Rocky Creek
Mar 5, 14	Chloriform	0.063	0.054
Mar 5, 14	Chlorodibromomethane	<0.001	<0.001
Mar 5, 14	Bromodichloromethane	.0023	0.0016
Mar 5, 14	Bromoform	<0.001	<0.001
Mar 5, 14	1,4-Difluorobenzene (sur.)	0.092	0.093
Mar 5, 14	4-Bromofluorobenzene (sur.)	0.103	0.099
Mar 5, 14	D4-1,2-Dichloroethane (sur.)	0.102	0.100
June 16, 2014	Chloriform	0.051	0.051
June 16, 2014	Chlorodibromomethane	<0.001	<0.001

June 16, 2014	Bromodichloromethane	.0015	0.0013
June 16, 2014	Bromoform	<0.001	<0.001
June 16, 2014	1,4-Difluorobenzene (sur.)	0.098	0.097
June 16, 2014	4-Bromofluorobenzene (sur.)	0.086	0.100
June 16, 2014	D4-1,2-Dichloroethane (sur.)	0.089	0.097
Sept 24, 2014	Chloriform	0.055	0.050
Sept 24, 2014	Chlorodibromomethane	<0.001	<0.001
Sept 24, 2014	Bromodichloromethane	.0041	0.0037
Sept 24, 2014	Bromoform	<0.001	<0.001
Sept 24, 2014	1,4-Difluorobenzene (sur.)	0.097	0.102
Sept 24, 2014	4-Bromofluorobenzene (sur.)	0.107	0.110
Sept 24, 2014	D4-1,2-Dichloroethane (sur.)	0.111	0.111
Dec 12, 2014	Chloriform	0.056	0.050
Dec 12, 2014	Chlorodibromomethane	<0.001	<0.001
Dec 12, 2014	Bromodichloromethane	.0020	0.0017
Dec 12, 2014	Bromoform	<0.001	<0.001
Dec 12, 2014	1,4-Difluorobenzene (sur.)	0.103	0.105
Dec 12, 2014	4-Bromofluorobenzene (sur.)	0.087	0.092
Dec 12, 2014	D4-1,2-Dichloroethane (sur.)	0.077	0.081