

## Holland Lake Turbidity Sampling

**2014**

Month	Complete	Ave	High	Low	Days > 1 NTU	Days > 5 NTU
January		0.868	1.766	0.599	5	0
February		0.646	1.444	0.556	0	0
March		0.745	6.142	0.415	3	0
April		0.534	1.083	0.441	0	0
May		0.657	1.078	0.523	0	0
June		0.705	0.853	0.463	3	0
July		0.462	0.756	0.363	0	0
August		0.570	1.271	0.422	0	0
Sept		#DIV/0!	0.000	0.000	0	0
Oct		0.755	1.949	0.409	6	0
Nov		1.055	1.169	1.012	6	0
Dec		#DIV/0!	0.000	0.000	0	0
Summary		#DIV/0!	6.142	0.000	23	0

6.3% 0.0%

## South End Chlorinator Turbidity Sampling

**2014**

Month	Complete	Ave	High	Low	Days > 1 NTU	Days > 5 NTU
January	Yes	0.321	0.885	0.192	0	0
February	Yes	0.314	0.500	0.166	0	0
March	Yes	0.315	0.811	0.178	0	0
April	Yes	0.246	2.449	0.147	1	0
May	Yes	0.270	0.347	0.183	0	0
June	Yes	0.331	1.713	0.180	1	0
July	Yes	0.284	0.432	0.145	0	0
August	Yes	0.166	0.422	0.000	0	0
Sept	Yes	0.225	0.502	0.093	0	0
oct	Yes	0.371	0.729	0.175	0	0
Nov	Yes	0.425	0.636	0.248	0	0
Dec	Yes	0.469	0.832	0.408	0	0
Summary		0.311	2.449	0.000	2	0

Date of Occurance: 1900-01-00

0.6% 0.1%

## Chicken Ladder Turbidity Sampling

**2014**

Month	Complete	Ave	High	Low	Days > 1 NTU	Days > 5 NTU
January		0.468	2.100	0.140	2	
February		0.664	1.860	0.170	7	
March		5.050	0.947	0.280	6	1
April		0.396	0.680	0.230		
May		0.336	0.470	0.260		
June		0.343	0.540	0.230		
July		0.314	0.460	0.230		
August		0.305	0.430	0.240		
Sept		0.335	0.580	0.220		
oct		0.000	0.000	0.000	5	
Nov		0.652	0.652	0.652		
Dec		0.000	0.000	0.000		
Summary		0.739	2.100	0.000	20	1

5.5%

0.3%