



Parks, Recreation, & Culture

Invitation to Tender
No. 2023-PRC-06

Arts and Heritage Hub

ADDENDUM #1

For further information:
Contact: Chris Barfoot
cbarfoot@ladysmith.ca
250.245.6421

Tender Issue Date: Thursday, June 29, 2023
Addendum #1: Friday, July 14, 2023
Site Visit: 10:00 a.m., Friday, August 11, 2023
Tender Closing: 2:00 p.m., Thursday, August 24
Tender Opening: 2:15 p.m., Thursday, August 24,
Ladysmith City Hall



Addendum #1: Invitation to Tender (ITT) No. 2023-PRC-06

Arts and Heritage Hub

This Addendum includes revisions to the ITT document.


Issued: July 14, 2023

This Addendum shall be read in conjunction with and considered as an integral part of the Invitation to Tender (ITT). Revisions supersede the information contained in the original ITT or previously issued Addendum. No consideration will be allowed for any extras due to any Proponents not being familiar with the contents of this Addendum. All other terms and conditions remain the same.

REVISIONS

INCLUDE attached 'Equal Letter Submittal' to the ITT document.

End of Addendum #1



Tender Addendum TA001

Contractor Reference: None

Date 2023.07.12

Project 2032 LAHH

Client Town of Ladysmith

The following addendum supersedes information contained in drawings, specifications and any previous addenda for the project to the extent referenced. This Addendum forms part of the tender documents and is subject to all of the conditions set out in the contract conditions.

Equal Letter - Aluminum Products

1. **Metro 2400T is not an acceptable** alternative to **Kawneer 1620UT/1602UT**. We don't have enough information on the ~~air/ water infiltration~~ testing of the product to prove that conforms with the building code requirements. Second, we need more information from the supplier that demonstrates that it can be used with an extended beauty cap of natural cedar as per drawing A031.
2. **Metro 2500T is not an acceptable** alternative to **CRL3250**. We don't have enough information on the air/ water infiltration testing of the product to prove that conforms with the building code requirements.
3. **Metro 500T** is an acceptable alternative as a commercial door.

Reason for Change: Similar Products - Metro Aluminum Products Ltd.

Distribution List

Chris Barfoot, Town of Ladysmith, cbarfoot@ladysmith.ca

Ben Checkwitch, Checkwitch Poiron Architects Inc., ben@cparch.ca

Per Hector Alcalá, Architect AIBC