



**LADYSMITH**

*Infrastructure Services*

**Invitation to Tender**

**No. 2022-IS-07**

**Addendum # 3**

# **4<sup>th</sup> Avenue Reconstruction Root Street to White Street**

For further information  
please contact:

**Patrick Ryan, P.Eng.**

**Herold Engineering**

**Phone: 250.751.8558**

**Fax: 250.751.8559**

[pryan@heroldengineering.com](mailto:pryan@heroldengineering.com)

**Tender Issue Date: Friday, June 17, 2022**

**Tender Closing Date: Tuesday, July 12, 2022 2:00 pm,**

**Location of Bid Opening: Town of Ladysmith City Hall,  
410 Esplanade, Ladysmith, BC**



**LADYSMITH**

**Attn:** All Bidders

**DATE:** July 5, 2022

**PROJECT No.:** 0037-064/5

**PROJECT NAME:**

Town of Ladysmith

4th Avenue Reconstruction

Invitation to Tender No. 2022-IS-07

**From:** Patrick Ryan, P.Eng.

---

**AD-03**

---

1. *This Addendum shall be read in conjunction with and considered as an integral part of the Contract Documents; revisions supercede the information contained in the original drawings, specifications or previously issued Addendum.*
2. *Tender Price submitted shall include all items of this Addendum.*
3. *No consideration will be allowed for any extras due to any bidder not being familiar with the contents of this Addendum.*

**The following Revisions apply to the Documents:**

**QUESTIONS & ANSWERS (continued from AD-02)**

**Q 21:** Where would we be paid for the survey monument reinstatement or is that by others?

**A21:** Monument reinstatement will be by others.

**Q 22:** The quantity for the 150 mm watermain looks like it includes the hydrant leads. Can You confirm.

**A22:** The 150 mm dia. hydrant leads and 150 mm dia. valves are to be included in the hydrant assembly line item 3.3

**Q 23:** I am only seeing 2 150 watermain bends not 4

**A23:** There are 4 total 150 mm dia. bends (2 vertical and 2 horizontal).

*End of Addendum #03*

  
Per: \_\_\_\_\_

Patrick Ryan, P.Eng.

CC: