

TOWN OF LADYSMITH

FRENCH STREET, METHUEN STREET, PARKHILL TERRACE & KITCHENER STREET WATERMAIN REPLACEMENTS

Question and Answer Sheet #1

November 17th, 2021

Question 1	2.4) Concrete Trench Cap - there is no STN 0+012 ?
Answer 1	Item 2.4 (Contract 1) of the Tender Form should refer to STN 1+012. This will be clarified in Addendum No. 1.
Question 2	Is there a pay item for the AC Removal ?
Answer 2	<p>AC pipe shall be removed where new piping connects to the old AC piping. The cost of working around AC pipe and disposing of it is to be included in the applicable tie-in prices listed under the Tender Form payment items "Watermain Tie-ins". AC pipe removal and disposal during tie-ins is covered by Measurement and Payment clause 4.3.6 of Section 02510.</p> <p>Where applicable, costs associated with the AC pipe shall also be included under Tender Form payment items "Hydrant Assemblies" which are covered by Measurement and Payment clause 4.2 of Section 02510. This will be clarified in Addendum No. 1.</p>
Question 3	Can you please specify the Concrete Boxes/ or plastic boxes as shown in the detail are required for the water service(s).
Answer 3	All new water service connections shall have concrete service boxes. Water service payment items in the Tender Form include the words "Concrete Service Box" and the notes under the Water Service Detail on the drawings include the words "METER BOXES SHALL BE CONCRETE WITH CAST IRON LID". Addendum No. 1 will clarify an acceptable make/model of concrete service box for the residential water service connections.
Question 4	Is the Contractor to supply the Water Meters for the services ?
Answer 4	All new water service connections shall include new water meters supplied and installed by the Contractor. Water service payment items in the Tender Form include the word "Meter". Measurement and Payment clause 4.3.3 in Section 02511 also includes the words "water meter".
Question 5	Are you able to provide to the interested contractors an Excel version of the schedule of Quantities , the Pdf Format in the tender package will not export correctly into excel and the due number of pay items this will make things a 100% more efficient.
Answer 5	See Addendum No. 1

