

TOWN OF LADYSMITH

**FRENCH STREET, METHUEN STREET, PARKHILL TERRACE &
KITCHENER STREET WATERMAIN REPLACEMENTS**

Question and Answer Sheet #3

November 25th, 2021

Question 1	Can you clarify if the watermain trench on Methuen St, is to be backfilled with import or can native be used, I ask this question because all the water main pay items are c/w imported backfill in the pay item descriptions except for 2.16 0.1 which has not got this in the description.
Answer 1	Import backfill is required for backfilling the watermain trench on Methuen Street (Tender Form payment item 2.16.1 - Contract 1). Measurement and payment clause 4.1.4 of Section 02510 states that import backfill is to be included.

NOTE: Please acknowledge receipt of this Question & Answer Sheet #3 by returning a signed copy of this document to Koers & Associates Engineering Ltd. by email to mpalmer@koers-eng.com.

Signature

Company Name

Date