



NOTES:

1. REFER TO SECTION 7 (STREETS) FOR STREET LIGHT AND SIDEWALK OFFSETS.
2. SERVICE BOXES SHALL HAVE MINIMUM SEPARATION OF 300mm.
3. REFER TO UTILITY CONSTRUCTION DRAWINGS FOR FURTHER DETAILS.

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TOWN OF LADYSMITH
 ENGINEERING STANDARD

PRIVATE UTILITIES
 UNDERGROUND ELECTRICAL
 TYPICAL SERVICE BOX LOCATION

DATE: OCT. 1994

APP. BY:

DRAWING No.
 T7

REV.
 00