



NOTES:

1. NOMINAL TRENCH WIDTH FOR FLUSHOUT IS 600mm
VALVE BOX NOT TO CONFLICT WITH CURB AND GUTTER
CURB AND GUTTER NOT SHOWN
2. LETTERING ON MANHOLE COVER SHALL REFER TO
"TOWN OF LADYSMITH WATERWORKS"
LETTERING SHALL BE 25 FLATTENED FACE GOTHIC
LETTERING WITH FACE OF LETTERS RAISED TO THE
SAME ELEVATION AS THE TOP OF THE RIBS
3. NOT TO BE USED IN AREAS WHERE WATER TABLE
COULD BE ABOVE FIRE HOSE CONNECTION
4. SURROUNDING GRADE TO DRAIN AWAY FROM COVER
5. CHAMBER MUST BE SELF DRAINING
6. 150 Ø X 200 PIPE TO BE PLACED AROUND PIPE
AT DRAIN HOLE TO PREVENT EROSION.
7. ONLY PRODUCTS APPROVED BY THE TOWN
ENGINEER WILL BE ACCEPTED FOR INSTALLATION

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TOWN OF LADYSMITH
ENGINEERING STANDARD

BELOW GRADE FLUSHOUT
DETAIL

DATE: FEB. 1994

APP. BY:

DRAWING No.

W2

REV.

01