



NOTES:

1. FOR HYDRANT OFFSETS REFER TO DESIGN DRAWINGS. AT NO TIME SHALL HYDRANTS BE CONSTRUCTED CLOSER THAN 0.6 METRES TO THE PROPERTY LINE.
2. HOSE AND PUMPER NOZZLE MUST FACE CURB.
3. HYDRANT FLANGES SHALL BE SET 100mm ABOVE A POINT 2% UP FROM THE TOP OF THE BACK OF THE CURB.
4. TYPE 2 HYDRANT CONNECTION (THRUST BLOCKED) TO BE USED ONLY WITH PRIOR APPROVAL OF THE ENGINEER.
5. HYDRANTS TO BE B.C. STANDARD APPROVED UNITS ARE:
C71P – TERMINAL CITY IRON WORKS
A442 – MUELLER MODERN CENTURION
M-67 – CLOW BRIGADIER
6. ONLY PRODUCTS APPROVED BY THE ENGINEER WILL BE ACCEPTED FOR INSTALLATION.

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TOWN OF LADYSMITH
ENGINEERING STANDARD

HYDRANT CONNECTION
TYPE 2

DATE: JAN. 1999

APP. BY:

DRAWING No.

W7

REV.

01