



NOTES:

1. CHAMBERS LOCATED IN UNPAVED AREAS REQUIRE 1.5m x 1.5m GRAVEL OR PAVED SURFACE AROUND COVER. PROJECT COVER 0 IN PAVEMENT OR 25 IN UNPAVED AREAS
2. ONLY PRODUCTS APPROVED BY THE TOWN ENGINEER WILL BE ACCEPTED FOR INSTALLATION

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



TOWN OF LADYSMITH
ENGINEERING STANDARD

TYPICAL METER CHAMBER

DATE: FEB. 1994

APP. BY:

DRAWING No.
W13

REV.
00