



NOTE:

1. INSIDE DROP TO BE USED ONLY WHERE SPECIFIED BY ENGINEER.
2. ALL INSIDE PIPE AND FITTINGS PVC DR 28/35.
3. THIS DRAWING SHOWS INSIDE DROP ONLY. SEE DRAWING S2 FOR ALL OTHER DETAILS PERTAINING TO MANHOLE REQUIREMENTS.

DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



**TOWN OF LADYSMITH**  
ENGINEERING STANDARD

INSIDE DROP MANHOLE

DATE: MAY 1996

APP. BY:

DRAWING No.  
**S3A**

REV.  
**00**