



NOTES:

1. PAVED SURFACE – 50mm ASPHALT (COMPACTED THICKNESS)
2. BASE – 100mm CRUSHED GRAVEL (20mm MINUS)
3. SUB-BASE – 250mm PIT RUN GRAVEL (75mm MINUS)
4. MOUNTABLE OR NON MOUNTABLE CURB AND GUTTER IN ACCORDANCE WITH STANDARD DRAWINGS C1 AND C2
5. EXTEND COMPACTED BASE MATERIAL 0.6m BEHIND AND TO THE TOP OF CURB WHERE NO SIDEWALK IS INSTALLED
6. DEPTHS OF SURFACING AND BASE GRAVELS ARE MINIMUM AND IN SOME CASES WILL HAVE TO BE INCREASED TO MEET MAXIMUM ALLOWABLE BENKELMAN BEAM DEFLECTION.
7. INSTALL CURB DRAIN ON HIGH SIDE OF ROAD WHERE REQUIRED BY THE ENGINEER
8. SUBJECT TO ENGINEERS APPROVAL SIDEWALK, STREETLIGHT AND HYDRANT OFFSETS MAY VARY.



**TOWN OF LADYSMITH**  
ENGINEERING STANDARD

20.0 m  
URBAN COLLECTOR  
Parking on both sides

DATE: Mar 2010

APP. BY:

DRAWING No.

R-2

REV.

00