



NOTES:

1. PAVED SURFACE – 75mm ASPHALT (COMPACTED THICKNESS)
2. BASE – 100mm CRUSHED GRAVEL (20mm MINUS)
3. SUB-BASE – 250mm PIT RUN GRAVEL (75mm MINUS)
4. MOUNTABLE MONOLITHIC CURB AND GUTTER IN ACCORDANCE WITH STANDARD DRAWING C1
5. EXTEND COMPACTED BASE MATERIAL 0.6m BEHIND AND TO THE TOP OF CURB WHERE NO SIDEWALK IS INSTALLED
6. DEPTHS OF SURFACING AND BASE GRAVELS ARE MINIMUM AND IN SOME CASES WILL HAVE TO BE INCREASED TO MEET MAXIMUM ALLOWABLE BENKELMAN BEAM DEFLECTION.
7. INSTALL CURB DRAIN ON HIGH SIDE OF ROAD WHERE REQUIRED BY THE ENGINEER
8. SUBJECT TO ENGINEERS APPROVAL SIDEWALK, STREETLIGHT AND HYDRANT OFFSETS MAY VARY.



TOWN OF LADYSMITH
ENGINEERING STANDARD

18.0m ROW
RURAL/INDUSTRIAL LOCAL

DATE: APRIL 2002

APP. BY:

DRAWING No.

R5

REV.

01